Elaflex hose certificate / 10 years / Conductivity and pressure test

ELAFLEX

INSPECTION CERTIFICATE 3.1
acc. to EN 10204:2004

Purchaser:

Order No.:
Order Date: 15.11.19
Confirmation No.: 1911031042
Confirmation Date: 19.11.19

Article and quantity:
2 x 20 m HO 65 C "Yellow Band"
both sides assembled with:
VC 50-2"x" BSP St

Serial number: 31042/1 1-2
Assembling date: 14.11.19
Hose prod. no.: 207930
Hose prod. date: 14.11.19

max. working pressure: PS 20 bar

Pressure test:
Above hoses were tested at 40 bar / 10 min. Test medium water. No leakages or faults were found.

Electrical conductivity:
The electrical conductivity was tested. The electrical resistance between the couplings, measured at the couplings, was recorded as:

31042/1 1-2 from 21400 Ohm to 22300 Ohm

Inspector: 25/11 NOV 2019

Result:
Regarding the pressure resistance and electrical conductivity above hoses correspond to the requirements of the ISO 1825 / EI 1529 and the agreed conditions of the order.
(conversion bar/psi: 20 bar ~ 300 psi / 40 bar ~ 600 psi)

Hamburg, the 25.11.19

Manager representative | Sales

ELAFLEX - Gummi Ehlers GmbH, Schnackenburgallee 121, 22525 Hamburg
Tel. +49 (40) 540 00 5-0 - Telefax +49 (40) 540 00 5-67

Product codes:

Reference:
PC022-00007
EAN13: -
UPC: -

Product attributes:

Product description:

Aviation hose compliance certificate to ISO 1825 / EI 1529 for: - Pressure test at 40 bar for 10min - Electrical continuity This certificate is compliant with the Hazrdous goods transportation agreement (ADR). It is valid for 10 years on every aviation fuelling site in France and in a foreign country.