

# Elaflex hose certificate / 10 years / Conductivity and pressure test

**ELAFLEX** 

INSPECTION CERTIFICATE 3.1  
acc. to EN 10204:2004

**Purchaser:**

Order No.:  
Order Date: 15.11.19  
Confirmation No.: 1911031542  
Confirmation Date: 19.11.19

Article and quantity	Serial number	Assembling date
2 x 20 m HD 63 C "Yellow Star" both sides assembled with: VO 55-25/ BSP 5/8	31042/1-2	11/19
	Hose prod. no.	Hose prod. date
	201920	10/19

max. working pressure: 20 bar

**Pressure test:**  
Above hoses tested at 40 bar / 10 min. Test medium water. No leakages or faults were found!

**Electrical conductivity:**  
The electrical conductivity was tested. The electrical resistance between the couplings, measured at the couplings, was recorded as:

31042/1-2 from 21400 Ohm to 22300 Ohm

Inspector: 

**Result:**  
Regarding the pressure resistance and electrical conductivity above hoses correspond to the requirements of the ISO 1825 / EI 1529 and the agreed conditions of the order (conversion target: 20 bar = 300 psi / 40 bar = 600 psi)

Hamburg, the 25.11.19

Manager  
representative

Sales

ELAFLEX - Garmes Eilers GmbH, Schrackenburgerallee 121, 22625 Hamburg  
Tel. +49 (40) 540 99 5-0 - Telefax +49 (40) 540 99 5-47

**Product codes:**

**Product attributes:**

Reference:  
PC022-00007  
EAN13: -  
UPC: -

## Product description:

Aviation hose compliance certificate to ISO 1825 / EI 1529 for: - Pressure test at 40 bar for 10min  
- Electrical continuity This certificate is compliant with the Hazardous goods transportation agreement (ADR). It is valid for 10 years on every aviation fuelling site in France and in a foreign country.