Elaflex hose certificate / 6 years / Conductivity and pressure test

ELAFLEX

INSPECTION CERTIFICATE 3.1
acc. to EN 10204:2004

Purchaser:

Order No.:
Order Date: 15.11.19
Confirmation No.: 1911031042
Confirmation Date: 19.11.19

Article and quantity:	Serial number	Assembling date
2 x 20 m HO 65 C "Yellow Band" both sides assembled with: VC 50-2"x" BSP SH	31042/1 1-2	4.11.19
	Hose prod. no.	Hose prod. date
	207930	4.11.19

max. working pressure: PS 20 bar

Pressure test:
Above hoses were tested at 40 bar / 10 min. Test medium water. No leakages or faults were found.

Electrical conductivity:
The electrical conductivity was tested. The electrical resistance between the couplings measured at the couplings was recorded as:

31042/1 1-2 from 21400 Ohm to 32300 Ohm

Inspector: 25/11 NOV 2019

Result:
Regarding the pressure resistance and electrical conductivity above hoses correspond to the requirements of the ISO 1825 / EI 1529 and the agreed conditions of the order (conversion bar/psi: 20 bar ~ 300 psi / 40 bar ~ 600 psi)

Hamburg, the 25.11.19

Manager representative | Sales

ELAFLEX - Gummi Ehlers GmbH, Schnackenburgallee 121, 22525 Hamburg
Tel. +49 (40) 540 00 5-0 - Telefax +49 (40) 540 00 5-67

Product codes:

Reference: PC022-00024
EAN13: -
UPC: -

Product attributes:

Product description: