

Certificat pour flexible aviation Elaflex / 10 ans / Conductivité et mise en pression

ELAFLEX 
INSPECTION CERTIFICATE 3.1
acc. to EN 10204:2004

Purchaser:

Order No.:
Order Date: 15.11.19
Confirmation No.: 1911021042
Confirmation Date: 19.11.19

Article and quantity: Serial number Assembling date
2 x 20 m HD 65 C "Yellow Star" 31042/1-2 11/19
both sides assembled with: HOSE and CO. HOSE prod. date
VO 55-25/ BSP 50 2019/20 10/19

max. working pressure: PG 20 bar

Pressure test:
Above hoses were tested at 40 bar / 10 min. Test medium water. No leakages or faults were found!

Electrical conductivity:
The electrical conductivity was tested. The electrical resistance between the couplings, measured at the couplings, was recorded as:
31042/1-2 from 21400 Ohm to 22300 Ohm

Inspector: 2019/10/20/2019

Result:
Regarding the pressure resistance and electrical conductivity above hoses correspond to the requirements of the ISO 1825 / EI 1529 and the agreed conditions of the order (conversion target: 20 bar = 300 psi / 40 bar = 600 psi)

Hamburg, the 25.11.19

Manager representative Sales

ELAFLEX - Garmesl Elites GmbH, Schnackenburgallee 121, 22625 Hamburg
Tel. +49 (40) 540 99 5-0 - Telefax +49 (40) 540 99 5-47

Codes de produit:

Attributs du produit:

Reference:
PC022-00007
EAN13: -
UPC: -

Description du produit:

Certificat de conformité ISO 1825 / EI 1529 pour flexible Elaflex en accord avec l'ADR. Validité: 10 ans.

Ne peut être commandé seul. Un certificat ne peut être commandé post-livraison.